

**Performance Comparison of Nb<sub>3</sub>Sn magnets at LBNL**

L. Chiesa, S. Caspi, M. Coccoli, D.R. Dietderich, S.A. Gourlay,  
R.R. Hafalia, A.F. Lietzke, A.D. McInturff, G. Sabbi, R.M. Scanlan

The Superconducting Magnet Group at the Lawrence Berkeley National Laboratory has been successfully developing Nb<sub>3</sub>Sn high-field dipole magnet technology for ten years. Noteworthy technology tests include D20 (4-layer cos $\theta$ , 13.5T, accelerator quality, 50mm bore ), and recent racetrack magnets: 1) RT1 (2-layer, 12T, no bore, no training), 2) RD3b (3-layer, 14.7T, 10mm bore), 3) Rd3c (3-layer, 12T, low-harmonic 35mm bore), and 4) some small Nb<sub>3</sub>Sn magnets that utilized some advanced technology.

We summarize the performance for these magnets, comparing 1) cable and geometry parameters, 2) RRR measurements, 3) training behavior, 4) ramp-rate sensitivity, 5) peak temperatures and voltages, and 6) fast flux adjustments that occur during ramping, most of which indicate conductor motions that are too small to trigger a quench.

Supported by Office of Science, High Energy & Nuclear Physics, Div. High Energy Physics, U.S. DOE, Contract DE-AC03-76SF00098.